



## Guide to interpret ATP-metry values - Industrial water -

Makeup water (in LOG eq.bact./ml):



Process water (in LOG eq.bact/ml):



We consider that when a measurement is:

- Below the warning threshold (**conformity**), the facility is under control,
- Between the warning threshold and the alarm threshold (**enhanced monitoring**), the facility does not present an immediate biohazard. A corrective action is recommended if 3 consecutive measurements are above the warning threshold,
- Above the alarm threshold (**corrective action**), the facility is not under control. A quick corrective action is recommended (control, cleaning, disinfection...).